



ATTESTATION of conformity with European Directives

Attestation Number: **2388AB050252006**
Product: **Solar Grid-tied Inverter**
Brand Name: **HAVELLS**
Model: **enviro GTi 24KT-NG, enviro GTi 15KT-NG**
Additional Model: **enviro GTi 17KT-NG, enviro GTi 20KT-NG, enviro GTi 22KT-NG**
Applicant: **Havells India Ltd.**
Address: **QRG Towers,2D,Sector 126, Expressway, Noida-201304-U.P.(INDIA)**
Technical Characteristics: **Max. DC input Voltage 1100V**
Operating MPPT Voltage Range 140~1000V
Max. PV Isc 36A/36A
Nominal Grid Voltage:3/N/PE, 380/400V
Max. Output Current: 3x38.3A
Nominal Grid Frequency: 50/60Hz

The submitted sample of the above equipment has been tested according to following standards:

| Standards | Report Number | Report date |
|--|-----------------|---------------|
| IEC 61000-6-3:2020 IEC 61000-3-11:2017 IEC 61000-3-12:2011 IEC 61000-6-1:2016 IEC 61000-6-2:2016 | CE2305WDG0252-3 | Oct. 17, 2023 |

Assistant Manager
EMC Department

Name: Madison Luo
Date: Oct. 17, 2023

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd.

Information given in this document is related to the tested specimen of the described electrical sample.