

VERIFICATION OF COMPLIANCE

No.: GZES2302002064PV01

Applicant: Havells India Ltd.
QRG Tower, 2D, Sector-126, Expressway, Noida-201304-
U.P.(INDIA)

Manufacturer: Havells India Ltd.
QRG Tower, 2D, Sector-126, Expressway, Noida-201304-
U.P.(INDIA)

Product Name: Solar Grid-tied Inverter

Product Description: Three Phase Inverter

Model No.: enviro GTi100KT-NG, enviro GTi110KT-NG.

Trade Mark: **HAVELLS**

Rating: Refer to page 2

Intended Use: PV System

Protection against Electric Shock: Class I

Additional Information (if any): IP 66

Firmware version: ARM V020010; DSPS V020010; DSPM V020010;

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: Refer to page 2

as shown in the

Test Report Number(s): GZES230200206401, GZES230200206402

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards.



David Guo
Senior Technical Manager
SGS-CSTC



2023-02-24

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at <https://www.sgs.com/en/terms-and-conditions>
Member of SGS Group (Société Générale de Surveillance)

No.:

GZES2302002064PV01

Other information added :
Ratings

Model	enviro GTi100KT-NG	enviro GTi110KT-NG
DC Input		
Max. DC voltage	1100 V	
Start-up operating voltage	200 V	
MPPT voltage range	180 V~1000 V	
Full power MPPT voltage range	550 V-850 V	
Max. input current	10*32 A	
Max. input short circuit current	10*50 A	
AC Output		
Rated AC Output power	100 kW	110 kW
Max. AC Output power	110 kVA	121 kVA
Max. output current	160 A	175 A
Nominal grid voltage	3/N/PE, 230 / 400 Vac	
Nominal output frequency	50 Hz/60 Hz	
Output power factor	1 default (adjustable +/-0.8)	
Operating temperature range	-30°C ~60°C	
Ingress protection	IP66	
Protective class	Class I	

Test

Standards: IEC 62116:2014. Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.
IEC 61727:2004. Photovoltaics (PV) systems - Characteristics of the utility interface.


 David Guo
 Senior Technical Manager
 SGS-CSTC



2023-02-24

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at <https://www.sgs.com/en/terms-and-conditions>

Member of SGS Group (Société Générale de Surveillance)